

TAB. č. 10 - Tepelný výkon a ročná potreba tepla pre navrhované funkčné plochy rozvojových lokalít do r. 2035

| Urbanistické obvody PDA | | | | Bývania | | | | Vybavenosti a rekr. | | Priemyselu | | Celkom | |
|-------------------------|-----------------|------|--------|-------------|-----|-------|--------|---------------------|--------|------------|-------|--------|--------|
| UO | Názov | UPC | FPB | Počet bytov | | MW | GJ/r | MW | GJ/r | MW | GJ/r | MW | GJ/r |
| | | | | IBV | HBV | | | | | | | | |
| A | B | C | D | E | F | G | H | I | J | K | L | M | N |
| 7 | Banská Vápenica | 7-2 | 7-2-4 | | | | | 0,070 | 510 | | | 0,070 | 510 |
| | | | 7-2-5 | | | | | 0,235 | 1 820 | | | 0,235 | 1 820 |
| | spolu 7 | | | | | | | 0,305 | 2 330 | | | 0,305 | 2 330 |
| 14 | Močidlá | 14-2 | 14-2-2 | 286 | | 3,605 | 23 165 | | | | | 3,605 | 23 165 |
| | | | 14-2-3 | 190 | | 2,395 | 15 390 | | | | | 2,395 | 15 390 |
| | spolu 14 | | | 476 | | 6,000 | 38 555 | | | | | 6,000 | 38 555 |
| 16 | Malá Lehôtka | 16-2 | 16-2-3 | 48 | | 0,605 | 3 890 | | | | | 0,605 | 3 890 |
| 19 | Vlčie Kúty | 19-1 | 19-1-3 | | 779 | 3,505 | 28 045 | | | | | 3,505 | 28 045 |
| 21 | Veľká Lehôtka | 21-2 | 21-2-4 | 24 | | 0,305 | 1 945 | | | | | 0,305 | 1 945 |
| | | | 21-2-6 | | | | | 0,095 | 745 | | | 0,095 | 745 |
| | spolu 21 | | | | | 0,305 | 1 945 | 0,095 | 745 | | | 0,400 | 2 690 |
| 23 | Prednádražie | 23-3 | 23-3-1 | | 100 | 0,450 | 3 600 | 1,545 | 11 655 | | | 1,995 | 15 255 |
| | | | 23-3-2 | | | | | | | 0,875 | 7 135 | 0,875 | 7 135 |
| | spolu 23 | | | | | 0,450 | 3 600 | 1,545 | 11 655 | 0,875 | 7 135 | 2,870 | 22 390 |